

I Airborne sound insulation

Technical report no.:	08.2005.15
Test institute:	Nüsing
Client:	SOLARLUX Aluminium Systeme GmbH Gewerbepark 9-11 49143 Bissendorf
Product/Component	<u>Five-panel slide & turn balcony glazing</u>
Designation	<u>SL 25</u>
Exterior dimensions (W x H)	<u>4035 mm x 1530 mm</u>
(Frame) Material	<u>Aluminium extruded profiles</u>
Airborne sound insulation index	<u>$R'_w = 17 \text{ dB}$</u>
Special features	<u>Glazing system 8 mm single pane safety glass</u>

The complete test report is available on request.

