

I Airborne sound insulation

Technical report no.: 08.2005.10
Test institute: Nüsing
Client: SOLARLUX Aluminium Systeme GmbH
Gewerbepark 9-11
49143 Bissendorf

Product/Component	Five-panel folding façade
Designation	SL 66
Exterior dimensions (W x H)	4140 mm x 2640 mm
(Rahmen) Material	Coniferous timber, laminated
Airborne sound insulation index	$R'_w = 38 \text{ dB}$
Special features	Akustex 29/38 sound attenuating glass 38 dB

The complete test report is available on request.

