

I Airborne sound insulation

Technical report no.: 08.2005.15
Test institute: Nüsing
Client: SOLARLUX Aluminium Systeme GmbH
Gewerbepark 9-11
49143 Bissendorf

Product/Component Five-panel slide & turn balcony glazing
Designation SL 25R
Exterior dimensions (W x H) 4035 mm x 1530 mm
(Frame) Material Aluminium extruded profiles
Airborne sound insulation index **$R'_w = 25 \text{ dB}$**
Special features Glazing system 8 mm single pane safety glass

The complete test report is available on request.

